CLIENT INFORMATION

Name: Ichabod Crane Central School District	Date of Sampling: 9/17/2016
Address: 2910 Route 9 Valatie, New York 12184	Samples Taken By:
Client Rep: Steven Marotta	Samples Taken By:

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Multiple Buildings
BLDG ADDRESS:	
CONTACT NAME & NUMBERS:	Steven Marotta (518) 758-7575 x 3501

RE-TEST NO. 1 SELECT LOCATIONS DRAWN ON SEPTEMBER 17TH, 2016

SAMPLE DATA

Sample Description ID (ID must match container label) — **Outlet Information**

Lab Sample #	Ichabod Sample No.	Location	Outlet Description	First Draw	LAB RESULTS COPPER		LAB RESULTS LEAD		
					<1.3 ppm	>1.3 ppm	< 15ppb	15-19ppb	>20ppb
1	HS-DW-20-2	100 Wing Fountain	Bubbler	x		1.87	<0.001		
2	HS-CF-23-2	Room 112	Faucet	x	0.29		0.001		
3	HS-DW-31-2	Café	Bubbler	x		1.55	<0.001		
4	HS-DW-104-2	400 Wing	Bubbler	x	1.07		<0.001		
5	HS-DW-108-2	300 Wing	Bubbler	x		1.37	<0.001		
6	HS-DW-109-2	300 Wing	Bubbler	x		1.33	<0.001		
7	HS-KF-118-1	M. Office Kitchen	Faucet	x	0.08		0.001		
8	MS-DW-1-2	Boy's Locker Room	Bubbler	x	0.94		0.006		
9	MS-KF-6-2	Kitchen	Faucet	x	0.24		0.002		
10	MS-KF-11-2	Kitchen Sprayer	Faucet	x	0.27		0.001		
11	MS-DW-13-2	Girl's Locker Room	Bubbler	x	0.94		<0.001		
12	MS-DW-26-2	100 Wing Fountain	Bubbler	x	0.58		<0.001		
13	MS-DW-37-2	200 Wing Fountain	Bubbler	x	0.6		<0.001		
14	MS-CF-66-2	Room 419	Faucet	x	0.52		0.001		
15	MS-CF-67-2	Room 419	Faucet	x	0.62		<0.001		
16	MS-KF-88-1	Room 421	Faucet	x	0.42		<0.001		
17	PS-KF-4-2	Kitchen	Faucet	x	0.07		0.014		
18	PS-KF-6-2	Kitchen Sprayer	Faucet	x	0.28		0.003		
19	PS-KF-7-2	Kitchen	Faucet	x	0.07		0.002		
20	PS-DW-50-2	Room 101	Bubbler	x	0.74		0.004		
21	PS-DW-66-2	Room 109	Bubbler	x	0.34		0.008		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for both lead and copper (Pb and Cu)

Lab: St Peters Bender Lab

Contact:

Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

Legend	
BF	Bathroom Faucet
CF	Classroom Faucet
DW	Drinking Water Fountain
KBF	Kitchen Bathroom Sink Faucet
KF	Kitchen Sink Faucet
LF	Library Faucet
NI	Nurse's Ice Machine
NF	Nurse's Sink Faucet
SC	Service Connection