



## CLIENT INFORMATION

Name: Ichabod Crane Central School District
Address: 2910 Route 9 Valatie, New York 12184
Client Rep: Steven Marotta

Date of Sampling:	9/17/2016
Samples Taken By:	
Samples Taken By:	

## SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Multiple Buildings
BLDG ADDRESS:	
CONTACT NAME & NUMBERS:	Steven Marotta (518) 758-7575 x 3501

## RE-TEST NO. 1 SELECT LOCATIONS DRAWN ON SEPTEMBER 17TH, 2016

--	--	--	--	--

## SAMPLE DATA

Sample Description ID (ID must match container label) Outlet Information

Lab Sample #	Ichabod Sample No.	Location	Outlet Description	First Draw	LAB RESULTS COPPER		LAB RESULTS LEAD			REMEDIATION
					<1.3 ppm	>1.3 ppm	< 15ppb	15-19ppb	>20ppb	
1	HS-DW-20-2	100 Wing Fountain	Bubbler	x		1.87	<0.001			
2	HS-CF-23-2	Room 112	Faucet	x	0.29		0.001			
3	HS-DW-31-2	Café	Bubbler	x		1.55	<0.001			
4	HS-DW-104-2	400 Wing	Bubbler	x	1.07		<0.001			
5	HS-DW-108-2	300 Wing	Bubbler	x		1.37	<0.001			
6	HS-DW-109-2	300 Wing	Bubbler	x		1.33	<0.001			
7	HS-KF-118-1	M. Office Kitchen	Faucet	x	0.08		0.001			
8	MS-DW-1-2	Boy's Locker Room	Bubbler	x	0.94		0.006			
9	MS-KF-6-2	Kitchen	Faucet	x	0.24		0.002			
10	MS-KF-11-2	Kitchen Sprayer	Faucet	x	0.27		0.001			
11	MS-DW-13-2	Girl's Locker Room	Bubbler	x	0.94		<0.001			
12	MS-DW-26-2	100 Wing Fountain	Bubbler	x	0.58		<0.001			
13	MS-DW-37-2	200 Wing Fountain	Bubbler	x	0.6		<0.001			
14	MS-CF-66-2	Room 419	Faucet	x	0.52		0.001			
15	MS-CF-67-2	Room 419	Faucet	x	0.62		<0.001			
16	MS-KF-88-1	Room 421	Faucet	x	0.42		<0.001			
17	PS-KF-4-2	Kitchen	Faucet	x	0.07		0.014			
18	PS-KF-6-2	Kitchen Sprayer	Faucet	x	0.28		0.003			
19	PS-KF-7-2	Kitchen	Faucet	x	0.07		0.002			
20	PS-DW-50-2	Room 101	Bubbler	x	0.74		0.004			
21	PS-DW-66-2	Room 109	Bubbler	x	0.34		0.008			

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

## CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:	Legend
				BF Bathroom Faucet
				CF Classroom Faucet
				DW Drinking Water Fountain
INSTRUCTIONS TO THE LABORATORY - Analyze all samples for both lead and copper (Pb and Cu)				KBF Kitchen Bathroom Sink Faucet
Lab: St Peters Bender Lab				KF Kitchen Sink Faucet
				LF Library Faucet
Contact:				NI Nurse's Ice Machine
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody				NF Nurse's Sink Faucet
				SC Service Connection